

To

The Principal,  
S.D. Vidya School,  
Jagadhri Road, Ambala Cantt - 133001.

No. 4856 Dated: 20/12/2024

Subject:

Building Structure Safety Certificate.

Reference:

Your office letter No.SDVS / 2024 - 2025 dated 05.11.2024.

The school building i.e. S.D. Vidya School, Jagadhri Road, Ambala Cantt - 133001 was visually inspected by the SDE P-6 alongwith JE in-charge. The school building was inspected visually and it found that the School Building Structure seems safe for running the school. Hence, the school building safety certificate for year 2024 - 2025 may be issued with following conditions: -

1. Building of this school should be repaired every year.
2. Water should not be allowed to stagnate around and on the roof of the Building.
3. If building is found cracked from anywhere, the same should be got vacated immediately and same should be got repaired immediately.
4. Institution authorities will be responsible for safety of building from every angle and Fire-Fighting equipment's should be in functional condition.
5. If the building of the school is to be extended, the same should be approved from reputed Structural Engineer.
6. Proof Checked structural drawings of the building should be sent to this office for record within 1 month from the issuing of NOC.
7. Institution shall also ensure safety precautions from false ceiling, vitrified used in dado.
8. NOC will be treated as cancelled by this office if the School violates any of the above points.

DA/NIL

Executive Engineer,  
Provincial Division No.1,  
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated:-

Copy of the above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No. 6, PWD B&R Br; Ambala Cantt for information w.r.t. this office No.492 dated 10.12.2024.

DA/ NIL

Executive Engineer,  
Provincial Division No.1,  
PWD B&R Br; Ambala Cantt.